

Date : -20.12.2019

## FORM B

[See Section 3(3) and rule 4(2) ]

Six monthly certificate to be given in every January and July  
by the owner or the occupier for Compliance of the  
Fire Prevention and Life Safety Measures.

## CERTIFICATE

Certified that I / We have carried out inspection of the Fire Prevention and Life Safety Measures installed  
in the following building or premises, namely :-

M/S - BTTC College, MB Marg, Colaba, Mumbai-400 001

I / We further certify that these installation in the above mentioned building are maintained in good  
repair and efficient condition during the period 1 January 2019 to 30 June 2019, as required under the  
provision of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah. III of 2007).  
The details of the inspection of installations carried out by me /us are mentioned in the report appended  
herewith.



Place : -Mumbai

Signature and Address of the Licensed Agency.

Date : -20.12.2019

License No. MFS-LA/2019/RF-42.

MFS-LA/2019/RD-46.

Date: 20.12.2019

## Appendix - I

### Inventory of the Fire Fighting System At M/S - BTTC College, MB Marg, Colaba, Mumbai-400 001

**A) DOWNCOMER SYSTEM.  
 (MANUAL OPERATION)**

SR NO	DESCRIPTION		REMARKS
1	ELECTRIC driven monoblock pump 7.5 HP booster pump.	Pump to give 3.2 Kg/cm <sup>2</sup> pressure on the foremost hydrant point & topmost sprinkler point.	OK
2	Sprinklers Per Floor	Working Ok	OK
3	Wet downcomer	100 mm GI C class pipe with single headed hydrant valve at each floor with first aid hose reel- 10NOS	OK
4	Hose box	MS hose box with lock & key arrangements including 01 NOS 15 meter long RRL hose pipe, having male & female adapters at both the end() end ( ss), one short branch pipe. Located near each hydrant point in the court yard. 11 NOS	OK
5	Fire man inlet	04 way fire man inlet. Located at ground floor.	OK
6	DOL STARTER, for booster pump.	Located at terrace terrace floor, working okay	OK

Place – Mumbai.

Date- 20.12.2019

*(Handwritten Signature)*



Signature and address of the licensed agency  
 License No. MFS-LA/2019/RF-42.  
 License NO. MFS-LA/2019/RD-46.



Date : -20.12.2019

**Appendix-2**

**Inventory of the Fire Fighting System At**  
**M/S - BTTC College, MB Marg, Colaba, Mumbai-400 001**

**A) Fire Alarm System.**

SR NO	DESCRIPTION		REMARKS
1	Fire alarm control panel.  Conventional fire alarm panel 8 zone.  Located on the ground floor  01 NOS.	Panel to give indication of floor number / zone add.	OK
2	Manual call point  Located on each floor in the lift lobby,  08 NOS	MCP to signal the fire alarm panel.	OK
3	Optical smoke / heat detectors.	To detect smoke in case of any fire, 60nos	OK
4	Conventional hooter, 08 nos	Give audible alarm of 85 db	OK

Place : -Mumbai

Date : -20.12.2019

Signature and Address of the Licensed Agency.

License No. MFS-LA/2019/RF-42.



LA/2019/RD-46.

*(Handwritten Signature)*